

**Brookhaven National Laboratory
Plant Engineering - E&CS Division
Engineering Change Notice Form**

PROJECT: CCWF II

JOB No. 11705

ECN Title: Load Tap Equipment

ECN No. 19

Affected Documents: Specification Section 16320

Requested Change (Attach sketch if applicable): Specification Section 16320, Paragraph 2.2.A.8 requires automatic load tap changing equipment. Recommend replacing with No-Load Tap Changer.

Requested by: D. Danseglio

Date: 12/31/09

Resolution: Replace Section 16320, Paragraph 2.2.A.8 with:

"Equip transformers with no-load tap changer with four (4) full capacity 2-1/2% primary taps, two (2) above and two (2) below rated high voltage. Provide an external operating handle at a convenient height with tap indicator and provisions for padlocking."

Approvals: A/E or Proj. Eng.:

Danseglio
Al Ryzhik

Date: 12/31/09

Project Coordinator:

Date: 12/31/09

Manager:

Date:

Contractor shall take the following action:

- ☐ Awaiting change order from P&PM
- ☒ Proceed with change as described
- ☒ Provide cost proposal for change as described

Distribution: E. W. Howell

Giffels

PPM

E&U

MPO

O&M

DOE

NSLS II

ECN File